

Patio/Sidewalk Handout

Excerpts from Village of Orland Hills Code of Ordinances

Printed From Website

§ Chapter 150.006

(6) All slabs will require that a minimum 10 gauge, welded wire mesh, or an equal be used in the construction.

§ Chapter 150.190 Concrete Flatwork

(A) Except as otherwise required all concrete flatwork shall have a minimum thickness of four inches.

(B) All concrete shall be placed on a granular base of at least four inches. Where a deeper base is required, granular fill may be used. Lifts may not exceed eight inches depth and each lift must be compacted.

(C) All concrete exposed to the weather must have a minimum cement content of six bags per cubic yard.